



RINA
150 YEARS

STATEMENT 2011/RA/01/124

the load tests of the spill containment units

t, have been carried out satisfactorily


MODEL	FOR	UDL UNIFORMLY DISTRIBUTED LOAD	DIMENSIONS	SUMP
VAPV007	1 x 1000 ltr IBC	1500 KG	142X142 CM H 100	1150 LIT.
VAPV010	2 x 1000 ltr IBC's	2500 KG	238X142 CM H 74	1400 LIT.
VAPF018	2 x 200 ltr drums	665 KG	102X142 CM H 52	370 LIT.
VAPF025	4 x 200 ltr drums	1000 KG	142X142 CM H 52	590 LIT.

This statement is issued for the uses allowed by the Law and Governments Acts in force .

Issued at Ravenna

on 30/03/2011



 *[Handwritten signature]*